



District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli

Test Report (Water)

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Report No.	2556	Date:	16/03/2026	Page No. 01
Customer Name	Our India International School			
Office Name and Address	Our India International School Kairana Road, Kandhla			
Ref Letter No & date	227/F-1/Admin/2026	Dt-13/03/2026		


Basic Details of Sample

District	Shamli	Block	Kandhla
Gram Panchayat	Kandhla	Village	Kandhla
Habitation	-----	Location/Site name	Our India International School Kairana Road, Kandhla
Water Source	Submersible	Sample No.	SML-2556
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	13/03/2026
Receiving Date	13/03/2026	Sample Collector	Wasil Chaudhary
Sample Depositor	Wasil Chaudhary	Sampling Method	IS 17614 (Part 1):2021
Analysis Strat date	16/03/2026	Analysis completion date	16/03/2026

Technical Data Analysis

S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E. Coli	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)
2	Total Coliform	CFU/100ml	0	0	0	IS 15185:2016 (RA 2021)

Note	1. This Certificate refers only to the particular sample(s) submitted for testing.
	2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
	3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
	4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Prepared by	Reviewed by	 Authorized by
--------------------	--------------------	---

End of Report

Laboratory Contact Details: Email-Id: upjnlabshamli@gmail.com, Mobile no.: +91 9528906867, +91 9917444912





District Level Water Analysis Laboratory of Uttar Pradesh Jal Nigam (Rural) Shamli




TC-13814

Test Report (Water)

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural), Shamli Uttar Pradesh, India

Report No.	2556	Date:	16/03/2026	Page No.	01	
Customer Name	Our India International School					
Office Name and Address	Our India International School Kairana Road, Kandhla					
Ref Letter No & date	227/F-1/Admin/2026	Dt-13/03/2026				
Basic Details of Sample						
District	Shamli	Block	Kandhla			
Gram Panchayat	Kandhla	Village	Kandhla			
Habitation	-----	Location/Site name	Our India International School Kairana Road, Kandhla			
Water Source	Submersible	Sample No.	SML-2556			
Quantity of Sample (ml)	1 ltr	Date of Sample Collect.	13/03/2026			
Receiving Date	13/03/2026	Sample Collector	Wasil Chaudhary			
Sample Depositor	Wasil Chaudhary	Sampling Method	IS 17614 (Part 1):2021			
Analysis Strat date	16/03/2026	Analysis completion date	16/03/2026			
Technical Data Analysis						
S. No.	Analysis Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5):2021
2	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7):2023
3	pH	-	7.06	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022
4	Turbidity	NTU	0.23	1	5	IS 3025 (Part 10):2017
5	TDS	mg/L	91	500	2000	IS 3025 (Part 16):2023
6	Chloride	mg/L	16.20	250	1000	IS 3025 (Part 32):2019
7	Total Alkalinity	mg/L	112	200	600	IS 3025 (Part 23):2023
8	Total Hardness	mg/L	120	200	600	IS 3025 (Part 21):2019
9	Sulphate	mg/L	17.38	200	400	APHA 24 th 4500 SO ₄ E. Turbidity Method:2023
10	Nitrate	mg/L	4.88	45	45	APHA 24 th 4500 NO ₃ B. UV Spec Method:2023
11	Fluoride	mg/L	0.116	1	1.5	APHA 24 th 4500-F C. Electrode Method:2023
12	Iron	mg/L	0.14	1	1	APHA 24 th 3500 Fe B. P. throline Method:2023
13	Calcium	mg/L	27.78	75	200	IS 3025 (Part 40):2019
14	Magnesium	mg/L	12.57	30	100	IS 3025 (Part 46):2023
Note	1. This Certificate refers only to the particular sample(s) submitted for testing.					
	2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
	3. The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.					
	4. Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.					
Prepared by			Reviewed by			
						
			Authorized by			

End of Report

Laboratory Contact Details: Email-Id: upjnlabshamli@gmail.com, Mobile no.: +91 9528906867, +91 9917444912

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No... 2556

Dated: 16/03/2026

It is certified that an inspection team headed by **Mr. Amit Kumar, Quality Manager** (Name of Officers with designation) from **U.P. Jal Nigam, Shamli (Rural)** inspected the **Our India International School, Kandhala, District-Shamli (U.P.)** (Name & Address of the school) on **13-03-2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no **2556** dated **16-03-2026** of **Executive Engineer, District Level Water Analysis Laboratory, Shamli (U.P.)** (PHED Lab) certified that the **Our India International School** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal:

Name : Amit Kumar

Designation : Quality Manager

Name & Address of the Office / Department : U.P. Jal Nigam, Shamli (Rural)

To,
Our India International School
Kandhala, District-Shamli (U.P.)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.